



NOTE:
1 - SCHEDULE 80 PVC OR EMT FOR RISER. FLEXIBLE CONDUIT MAY BE USED FROM DISCONNECT. DO NOT RUN FLEXIBLE CONDUIT UNDERGROUND. BREAKER CAPACITY.
2 - 200 AMP COMMERCIAL METER POLE (BARN, WATER PUMP, ETC...) WILL NEED TO BE UPGRADED TO 3/0 COPPER CONDUCTOR WITH 1/0 NEUTRAL

WIRE SIZES				
AMPS	TYPE	CONDUCTOR	NEUTRAL	EQ. GROUND
100	COPPER	#3	#4	#8
100	ALUMINUM	#1	#2	#6
200	COPPER	2/0	#1	#4
200	ALUMINUM	4/0	2/0	#4

MINIMUM MOBILE HOME AND RV POLE REQUIREMENTS

SCALE: NOT TO SCALE

DATE: 07-02-2014

DRAWN BY: BRADY T. ALLRED

SHEET NO. 1

LAWRENCEBURG UTILITY SYSTEMS

1607 N LOCUST AVENUE
LAWRENCEBURG, TN 38464
(931) 762-7161