



- ENGINEERING DEPARTMENT IS TO SPOT POLES
- WIRE TO BE DIRECT BURIAL #6 USE, UF
- 9' POLE, 2' SET INTO GROUND
- CUSTOMER IS TO SUPPLY WIRE FROM METER TO TRANSFORMER
- MINIMUM OF 15' LEAD FROM POLE
- CUSTOMER IS TO SET POLE
- MUST BE INSPECTED BY STATE INSPECTOR BEFORE LUS WILL CONNECT
- TEMP SERVICE DOES NOT REQUIRE MILBANK METERBASE
- 3" CONDUIT TO HOUSE

SINGLE PH UG TRANSFORMER, UG TEMP SERVICE INSTALLATION GUIDE		
SCALE: NOT TO SCALE	DATE: 12-16-2014	
DRAWN BY: BRADY T. ALLRED		SHEET NO. 1
LAWRENCEBURG UTILITY SYSTEMS		
1607 N LOCUST AVENUE LAWRENCEBURG, TN 38464 (931) 762-7161		